






Regione Emilia Romagna
Comune di Ferrara

IMPIANTO FOTOVOLTAICO E OPERE CONNESSE

Potenza Impianto 9,573 MWp







PROPONENTE

LIGHTSOURCE RENEWABLE ENERGY ITALY SPV 14 S.R.L.
 VIA G. LEOPARDI, 7 - 20123 MILANO (MI) - P.IVA: 12593780963 – PEC: lightsourcespv_14@legalmail.it


PROGETTAZIONE

Ing. Antonello Ruttilio 
 Via R. Zandonai, 4 – 44124 – FERRARA IT - P.IVA: 00522150382 – PEC: incico@pec.it
 Tel.: +39 0532 202613 – email: a.ruttilio@incico.com

COLLABORAZIONI

Ing. Lorenzo Stocchino 
 Via R. Zandonai, 4 – 44124 – FERRARA IT - P.IVA: 00522150382 – PEC: incico@pec.it
 Tel.: +39 0532 202613 – email: l.stocchino@incico.com

COORDINAMENTO PROGETTUALE

SOLAR IT S.R.L. 
 VIA I. ALPI 4 – 46100 - MANTOVA IT - P.IVA: 02627240209 – PEC: solarit@lamiappec.it
 Tel.: +390425 072 257– email: info@solaritglobal.com

TITOLO ELABORATO			
CALCOLO DELLA PRODUCIBILITÀ			
LIVELLO DI PROGETTAZIONE	CODICE ELABORATO	FILE NAME	DATA
DEFINITIVO	23-LS15787-IT-CONA-PI-R01	23-LS15787-IT-CONA-PI-R01_0	08/03/2023

REVISIONI					
REV.	DATA	DESCRIZIONE	ESEGUITO	VERIFICATO	APPROVATO
0	08/03/2023	Emesso per filing	MCA	LST	ARU

CALCOLO DELLA PRODUCIBILITÀ



Project: Cona LSBP 2023

Variant: Nuova variante di simulazione

PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2

Project summary

Geographical Site

Cona
Italia

Situation

Latitude 44.80 °N
Longitude 11.71 °E
Altitude 8 m
Time zone UTC+1

Project settings

Albedo 0.20

Meteo data

Cona
Meteonorm 8.1 (1991-2012), Sat=100% - Sintetico

System summary

Grid-Connected System

Simulation for year no 10

Tracking system

PV Field Orientation

Orientation

Tracking plane, horizontal N-S axis
Axis azimuth 0 °

Tracking algorithm

Astronomic calculation

Near Shadings

Linear shadings
Diffuse shading Automatic

System information

PV Array

Nb. of modules 13676 units
Pnom total 9573 kWp

Inverters

Nb. of units 3 units
Pnom total 10.31 MWac
Pnom ratio 0.928

User's needs

Fixed constant load
20.00 kW
Global
175 MWh/Year

Results summary

Produced Energy	11807485 kWh/year	Specific production	1233 kWh/kWp/year	Perf. Ratio PR	68.49 %
Used Energy	175200 kWh/year			Solar Fraction SF	43.77 %

Table of contents

Project and results summary	2
General parameters, PV Array Characteristics, System losses	3
Near shading definition - Iso-shadings diagram	5
Main results	6
Loss diagram	7
Predef. graphs	8
Single-line diagram	14



Project: Cona LSBP 2023
Variant: Nuova variante di simulazione

PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2

General parameters

Grid-Connected System

PV Field Orientation

Orientation

Tracking plane, horizontal N-S axis
Axis azimuth 0 °

Models used

Transposition Perez
Diffuse Perez, Meteonorm
Circumsolar separate

Horizon

Free Horizon

Tracking system

Tracking algorithm

Astronomic calculation

Near Shadings

Linear shadings
Diffuse shading Automatic

Trackers configuration

Nb. of trackers 526 units

Identical arrays

Sizes

Tracker Spacing 8.70 m
Collector width 4.79 m
Ground Cov. Ratio (GCR) 55.0 %
Phi min / max. -/+ 90.0 °

Shading limit angles

Phi limits for BT -/+ 56.5 °

User's needs

Fixed constant load
20.00 kW
Global
175 MWh/Year

PV Array Characteristics

PV module

Manufacturer Risen Solar
Model RSM132-8-700BHDG
(Custom parameters definition)

Unit Nom. Power 700 Wp
Number of PV modules 13676 units
Nominal (STC) 9573 kWp
Modules 526 Strings x 26 In series

At operating cond. (50°C)

Pmpp 8762 kWp
U mpp 990 V
I mpp 8851 A

Total PV power

Nominal (STC) 9573 kWp
Total 13676 modules
Module area 42482 m²

Inverter

Manufacturer Sungrow
Model SG3400-HV-20
(Custom parameters definition)

Unit Nom. Power 3437 kWac
Number of inverters 3 units
Total power 10311 kWac
Operating voltage 875-1300 V
Max. power (=>25°C) 3593 kWac
Pnom ratio (DC:AC) 0.93
Power sharing within this inverter

Total inverter power

Total power 10311 kWac
Max. power 10779 kWac
Number of inverters 3 units
Pnom ratio 0.93

Array losses

Array Soiling Losses

Loss Fraction 2.0 %

LID - Light Induced Degradation

Loss Fraction 2.0 %

Thermal Loss factor

Module temperature according to irradiance
Uc (const) 29.0 W/m²K
Uv (wind) 0.0 W/m²K/m/s

Module Quality Loss

Loss Fraction -0.8 %

DC wiring losses

Global array res. 1.9 mΩ
Loss Fraction 1.5 % at STC

Module mismatch losses

Loss Fraction 2.0 % at MPP



PVsyst V7.3.2

VC6, Simulation date:

07/03/23 17:01

with v7.3.2

Array losses

Strings Mismatch loss

Loss Fraction 0.1 %

Module average degradation

Year no 10

Loss factor 0.4 %/year

Mismatch due to degradation

Imp RMS dispersion 0.4 %/year

Vmp RMS dispersion 0.4 %/year

IAM loss factor

Incidence effect (IAM): Fresnel, AR coating, n(glass)=1.526, n(AR)=1.290

0°	30°	50°	60°	70°	75°	80°	85°	90°
1.000	0.999	0.987	0.962	0.892	0.816	0.681	0.440	0.000

System losses

Unavailability of the system

Time fraction 2.0 %
7.3 days,
3 periods

Auxiliaries loss

constant (fans) 20.0 kW
0.0 kW from Power thresh.
Proportionnal to Power 10.0 W/kW
0.0 kW from Power thresh.
Night aux. cons. 10.0 kW

AC wiring losses

Inv. output line up to MV transfo

Inverter voltage 600 Vac tri
Loss Fraction 0.00 % at STC

Inverter: SG3400-HV-20

Wire section (3 Inv.) Copper 3 x 3 x 2000 mm²
Average wires length 0 m

MV line up to Injection

MV Voltage 20 kV
Average each inverter
Wires Copper 3 x 120 mm²
Length 200 m
Loss Fraction 0.02 % at STC

AC losses in transformers

MV transfo

Medium voltage 20 kV

One transfo parameters

Nominal power at STC 3.16 MVA
Iron Loss (night disconnect) 3.44 kVA
Iron loss fraction 0.11 % at STC
Copper loss 29.03 kVA
Copper loss fraction 0.92 % at STC
Coils equivalent resistance 3 x 1.05 mΩ

Operating losses at STC (full system)

Nb. identical MV transfos 3
Nominal power at STC 9.48 MVA
Iron loss (night disconnect) 10.33 kVA
Copper loss 87.10 kVA




PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2


Near shadings parameter

Perspective of the PV-field and surrounding shading scene



Iso-shadings diagram

Orientation #1





Project: Cona LSBP 2023

Variant: Nuova variante di simulazione

PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2


Main results

System Production


Produced Energy 11807485 kWh/year
Used Energy 175200 kWh/year

Specific production 1233 kWh/kWp/year
Performance Ratio PR 68.49 %
Solar Fraction SF 43.77 %

Normalized productions (per installed kWp)



Performance Ratio PR



Balances and main results

	GlobHor	DiffHor	T_Amb	GlobInc	GlobEff	EArray	E_User	PR	E_Grid	EFrGrid
	kWh/m ²	kWh/m ²	°C	kWh/m ²	kWh/m ²	kWh	kWh	ratio	kWh	kWh
January	41.3	25.33	3.03	57.6	44.0	390319	14880	0.626	340909	10352
February	54.9	29.81	5.06	74.1	60.8	532663	13440	0.711	500026	8733
March	105.5	56.66	10.08	141.8	117.7	1011801	14880	0.714	962503	8216
April	133.8	63.33	14.10	180.5	152.8	1279874	14400	0.711	1222042	7262
May	177.2	79.10	19.02	236.9	204.7	1679380	14880	0.713	1608346	6473
June	191.7	86.40	23.41	254.9	223.3	1804185	14400	0.664	1612663	6720
July	195.8	87.27	25.83	264.0	229.4	1835725	14880	0.650	1634104	7065
August	169.5	75.01	25.35	227.2	196.1	1575623	14880	0.698	1509396	7040
September	118.0	55.69	19.98	165.1	136.5	1123470	14400	0.682	1071339	7645
October	77.2	41.93	15.56	106.6	86.4	730340	14880	0.682	689523	9020
November	41.6	27.88	9.60	50.1	41.2	355923	14400	0.690	326517	9683
December	31.9	21.80	4.27	42.0	32.0	281526	14880	0.641	253436	10312
Year	1338.7	650.22	14.66	1800.9	1525.1	12600828	175200	0.685	11730804	98519

Legends


GlobHor	Global horizontal irradiation	EArray	Effective energy at the output of the array
DiffHor	Horizontal diffuse irradiation	E_User	Energy supplied to the user
T_Amb	Ambient Temperature	PR	Performance Ratio
GlobInc	Global incident in coll. plane	E_Grid	Energy injected into grid
GlobEff	Effective Global, corr. for IAM and shadings	EFrGrid	Energy from the grid



PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2

Loss diagram






PVsyst V7.3.2


VC6, Simulation date:
07/03/23 17:01
with v7.3.2

Predef. graphs

Energia incidente di riferimento su piano collettori



Fattori normalizzati di produzione e di perdita





PVsyst V7.3.2


VC6, Simulation date:

07/03/23 17:01


with v7.3.2

Predef. graphs

Distribuzione irraggiamento incidente



Coda della distribuzione di irradiazione incidente





PVsyst V7.3.2

VC6, Simulation date:

07/03/23 17:01

with v7.3.2

Predef. graphs

Temperatura del campo vs. irradiazione efficace





Diagramma giornaliero entrata/uscita





PVsyst V7.3.2


VC6, Simulation date:

07/03/23 17:01


with v7.3.2

Predef. graphs

Energia giornaliera in uscita sistema



Distribuzione potenza dell'impianto





PVsyst V7.3.2


VC6, Simulation date:

07/03/23 17:01


with v7.3.2

Predef. graphs

Distribuzione potenza in uscita sistema



Coda della distribuzione della potenza in uscita





PVsyst V7.3.2


VC6, Simulation date:

07/03/23 17:01


with v7.3.2

Predef. graphs

Distribuzione tensione impianto



Distribuzione temperatura impianto






PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2

Single-line diagram



PV module	RSM132-8-700BHDG
Inverter	SG3400-HV-20
String	26 x RSM132-8-700BHDG

Cona LSBP 2023

AREA TECNICA (Italy)

VC6 : Nuova variante di simulazione

07/03/23



PVsyst V7.3.2

VC6, Simulato su

07/03/23 17:01

con v7.3.2

Nuova variante di simulazione
Coefficienti di rendimento normalizzati

	Yr	Lc	Ya	Ls	Yf	Lcr	Lsr	PR
	kWh/m ² /day	kWh/kWp/day	kWh/kWp/day	kWh/kWp/day	kWh/kWp/day	ratio	ratio	ratio
January	1.86	0.54	1.32	0.15	1.16	0.293	0.081	0.626
February	2.65	0.66	1.99	0.10	1.88	0.249	0.039	0.711
March	4.58	1.17	3.41	0.14	3.27	0.255	0.031	0.714
April	6.02	1.56	4.46	0.18	4.28	0.259	0.029	0.711
May	7.64	1.98	5.66	0.21	5.45	0.260	0.028	0.713
June	8.50	2.22	6.28	0.64	5.64	0.261	0.075	0.664
July	8.52	2.33	6.19	0.65	5.53	0.274	0.077	0.650
August	7.33	2.02	5.31	0.20	5.11	0.275	0.027	0.698
September	5.50	1.59	3.91	0.16	3.75	0.289	0.029	0.682
October	3.44	0.98	2.46	0.12	2.34	0.284	0.034	0.682
November	1.67	0.43	1.24	0.09	1.15	0.258	0.051	0.690
December	1.36	0.41	0.95	0.08	0.87	0.300	0.058	0.641
Year	4.93	1.33	3.61	0.23	3.38	0.269	0.046	0.685

Al fine di facilitare il confronto tra più impianti fotovoltaici, il JRC (Centro comune di ricerca europeo) ha introdotto il seguente Indice di prestazione, ora fissato nella norma IEC EN 61724.

Questi indicatori sono correlati all'energia incidente G_{inc} nel piano del collettore e sono normalizzati da P_{nom} = Potenza nominale installata dell'array a STC, come fornito dal produttore del modulo fotovoltaico [kWp].

Pertanto sono indipendenti dalla dimensione dell'array, dalla situazione geografica e dall'orientamento del campo.

In queste definizioni le energie di rendimento sono espresse come [kWh / KWp / giorno]. In altre parole, tali grandezze sono numericamente pari al Tempo di funzionamento equivalente con un irraggiamento costante di 1 kW/m², ovvero possono essere espresse anche come [Ore/ giorno] con funzionamento a 1 kW/m², oppure [kWh/ m²/giorno] (vedi nota sotto).

Definiamo le seguenti quantità:

- Yr = Sistema di riferimento Yield è l'array ideale Yield secondo P_{nom} come definito dal produttore, senza alcuna perdita. Si può capire come ogni kWh incidente dovrebbe idealmente produrre la potenza nominale dell'array P_{nom} durante un'ora. Yr è numericamente uguale all'energia incidente nel piano dell'array, espressa in [kWh/m²/giorno].
- Ya = Array Yield è l'energia prodotta giornalmente dall'array, riferita alla potenza nominale [kWh / KWp / giorno].
- Yf = Resa impianto è l'energia utile giornaliera dell'impianto, riferita alla potenza nominale [kWh / KWp / giorno].
- Lc = Collection Loss = Yr - Ya, sono le perdite dell'array, comprese le perdite termiche, di cablaggio, di qualità del modulo, mismatch e IAM, ombreggiamento, sporcizia, MPP, perdite di regolazione, nonché tutte le altre inefficienze.
- Ls = System Loss = Ya - Yf, include la perdita dell'inverter nei sistemi connessi alla rete o le inefficienze di batteria nei sistemi stand-alone.
- PR = Performance Ratio = Yf / Yr, è l'efficienza globale del sistema rispetto alla potenza nominale installata e all'energia incidente.

Per i sistemi stand-alone (o ogni sistema con carico limitato), introduciamo anche:

- Lu = Energia non utilizzata, l'energia potenzialmente disponibile all'uscita dell'array, che non può essere utilizzata perché il sistema è "saturato" (batteria carica o carico limitato nel sistema DC-grid).

Questo dovrebbe essere determinato durante la simulazione, e abbiamo: $Ya = Yr - Lu - Lc$.

In questo caso Lc è la perdita di raccolta, solo quando il sistema è in grado di utilizzare l'energia prodotta.



Project: Cona LSBP 2023

Variant: Nuova variante di simulazione

PVsyst V7.3.2

VC6, Simulation date:
07/03/23 17:01
with v7.3.2

AREA TECNICA (Italy)

Project summary

Geographical Site

Cona
Italia

Situation

Latitude 44.80 °N
Longitude 11.71 °E
Altitude 8 m
Time zone UTC+1

Project settings

Albedo 0.20

Meteo data

Cona
Meteonorm 8.1 (1991-2012), Sat=100% - Sintetico

System summary

Grid-Connected System

Simulation for year no 10

Tracking system

PV Field Orientation

Orientation

Tracking plane, horizontal N-S axis
Axis azimuth 0 °

Tracking algorithm

Astronomic calculation

Near Shadings

Linear shadings
Diffuse shading Automatic

System information

PV Array

Nb. of modules 13676 units
Pnom total 9573 kWp

Inverters

Nb. of units 3 units
Pnom total 10.31 MWac
Pnom ratio 0.928

User's needs

Fixed constant load
20.00 kW
Global
175 MWh/Year

Results summary

Produced Energy	11807.5 MWh/year	Specific production	1233 kWh/kWp/year	Perf. Ratio PR	68.49 %
Used Energy	175.2 MWh/year			Solar Fraction SF	43.77 %

Table of contents

Project and results summary